

POWERED BY





CERTIFIED BY







80 KVA

3 PHASE

50 Hz

GENERATING SET MODEL (UPS P 80)			
Output Ratings	Prime	Standby	
380-415 V, 3 ph, 50 Hz, 1500 rpm	80 KVA	88 KVA	
	64 KW	70 KW	
380-415 V, 3 ph, 60 Hz, 1800 rpm	92 KVA	102KVA	
	73.8 KW	81.7 KW	

ENGINE / TECHNICAL DATA

Ratings at 0.8 Power Factor

Engine Make	Per	kins
Engine Model	1104A-44TG2	
Governing Type	Mechanical	
Number of Cylinders	4	
Cylinder Arrangement	Vertical in line	
Bore and Stroke mm	105 x 127	
Displacement / Cubic Capacity litres	4	.4
Induction System	Turboc	harged
Cycle	4 stroke	
Combustion System	Direct Injection	
Compression Ratio	17.25:1	
Rotation	Anti-clockwise, viewed from flywheel	
Cooling System	Water - cooled	
Frequency and Engine Speed	50Hz & 1500rpm	60 Hz & 1800rpm
Constant Province Province Iday (Inc.)	70.4 (00.4)	00.7 (100.0)
Gross Engine Power kW (hp)	73.4 (98.4)	80.7 (108.2)
Fuel Consumption @ 50% load L/hr	11.3	13.5
@ 75% load L∕hr	16.9	18.7
@ 100% load L/hr	20.6	23.7
Total Lubrication System Capacity litres	8	8
Total Coolant Capacity (inc. radiator) litres	13.0	13.0
Exhaust Temperature: °C	580	580

92 KVA 3 PHASE

ALTERNATOR DATA		
Make	UPS / LEROY SOMER	
Model	UPS224G/ LSA(TAL)044B	
No. of bearing	s 1	
Insulation clas	ss H	
Wires	6 /12	
Ingress Protec	etion IP23	
Excitation Sys	tem SHUNT	
Winding Pitch	2/3	

Overspeed	2250 mn ⁻¹
Voltage Regulation (steady)	± 1%

CONTROL PANEL	
Make	Deep Sea
Model	4000 SERIES

The **DSE 4000** Series is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite software.

Metering and Alarm indications:

- Generator frequency
- · Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- · Hours run counter
- Battery volts
- Fail to start/stop
- Emergency stop
- · Failed to reach loading voltage/frequency
- Charge fail
- Low DC voltage
- · CAN diagnostics and CAN fail/error

Image for illustrative purposes only





E-mail: info@upsgenerator.com P.O.BOX: 122333 | F3-18, Sharjah Airport Free Zone (SAIF ZONE) Web.: www.upsgenerator.com

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine.

50Hz

2. ENGINE FILTRATION SYSTEM

- · Cartridge type dry air filter.
- Two Cartridge type fuel filters.
- · Full flow lube oil filter.

All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

4. EXHAUST SYSTEM

Exhaust gas flow 13.3 m^3/min Maximum allowable back pressure 10.0 (kPa)

5. CIRCUT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

7. ALTERNATOR

- 7.1 INSULATION SYSTEMThe insulation system is Class H.
- All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin.
- Heavy coat of antitracking varnish additional protection against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 1\%$. Nominal adjustment by means of a trim pot incorporated on the AVR.

8. MOUNTING ARRANGEMENT

8.1 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.3 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

9. FACTORY TEST

- The Generating set is load tested before dispatch
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.


13. WARRANTY


All of the Generating Sets are covered under a warranty policy for a period of 12 months or 1000 working hours, Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries)


In line with continuous product development, we reserve the right to change specifications without notice.


STANDARD GENERATOR DIMENSION AND WEIGHT

Silent Type (with Soundproof Canopy)











Open Type (without Soundproof Canopy)





P.O.BOX: 122333 | F3-18, Sharjah Airport Free Zone (SAIF ZONE) | E-mail: info@upsgenerator.com Web.: www.upsgenerator.com